

Experiments with reducing energy use at the National Archives & Records Administration



Mark Ormsby

*The National Archives and Records Administration (NARA)
preserves, protects, and makes accessible those records
deemed to have permanent, historical value*



10+ billion pages of paper-based records
Photographs, audio-visual, cartographic, electronic ...

Total holdings ~ 4.4 million cubic feet (125,000 cubic meters)

Archives 2 – College Park, Maryland

Constructed 1993



2,400,000 cubic feet
archival storage space

(68,000 cubic meters)



Archives 2

Constructed 1993



Yearly **electricity** cost ~1996

Estimated: \$2 million (£ 1.4 million, € 1.8 million)

Actual: \$3.1 million (£ 2.2 million, € 2.8 million)

Lighting ~ 50% of electricity use

Most of the rest consumed by air handler units (AHUs)

Stack Air Handler Unit (AHU)



Archives 2 Stacks

630 AHU 31A + 31B	631 AHU 24	650 AHU 23		
	↔			
530 AHU 30	532 AHU 22 35% PHOTO	550 AHU 21	570 AHU 11 2 FANS	
↕				
430 AHU 29	431 AHU 20 30% PHOTO	450 AHU 19	470 AHU 10	490 AHU 9
			↔	
330 AHU 28	331 AHU 18	350 AHU 17	370 AHU 8	390 AHU 7
↕	↔		↔	
230 AHU 27	231 AHU 16	250 AHU 15	270 AHU 6	290 AHU 5
	↔		↔	
130 AHU 26 2 FANS	131 AHU 14	150 AHU 13	170 AHU 4	190 AHU 3
	↔		↔	
				B190 AHU 2

Summer 1995 – Redundant AHU Pairs



Use one AHU to supply two stacks
Shut down the other unit during the day

Tests of 4 stacks showed that
temperature and RH remained within specification

Expanded to shut down 12 of 28 stack AHUs during peak demand periods

December 1996

Reduced stack air exchange rate
from 6 per hour to ~ 4.8 per hour
by mechanical modifications to fans

Air exchange rate initially based
on pollutant specifications



Specifications for Air Pollutants in Storage and Exhibit Areas

SO ₂	1.0 ppb	2.7 µg/m ³
NO ₂	2.6	5.0
Ozone	2.0	4.0
Acetic Acid	4.0	10.0
Formaldehyde	4.0	5.0

Stacks designed with 90% recirculated air
6 air changes per hour

Archives 2 Baseline – FY2003

Fiscal Year	Total Utility Cost (include water)	Electric (MWH)	Natural Gas (Thous. Cu. Ft.)	Energy Usage (KBtu)	Energy Intensity (Kbtu/Gsf)	% Energy Intensity Reduction vs FY2003
FY2003	\$3,175,935	47,578	142,883	309,600,000	173	Baseline

£2,200,000

€2,900,000



2006 - Taking further advantage of redundant AHU pairs

Previously one unit off during the day
but all units on at night
to increase air exchange rate

Changed to 3-day cycles
with one unit serving both stacks at all times



2006 - Taking further advantage of redundant AHU pairs

Acetic acid and formaldehyde
measured in 5 stacks
before and 5 months after
3-day shutdown cycles started

Conclusion: running two stacks on one AHU
caused no significant difference in pollutant levels
or temperature and RH control





Archives II Energy and Greenhouse Gas (GHG) Consumption and Savings

Fiscal Year	Total Utility Cost (include water)	Electric (MWH)	Natural Gas (Thous. Cu. Ft.)	Energy Usage (KBtu)	Energy Intensity (Kbtu/Gsf)	% Energy Intensity Reduction vs FY2003	GHG (Metric Ton CO2)	GHG Savings vs FY2008 (Ton)
FY2003	\$3,175,935	47,578	142,883	309,600,000	173	Baseline		
FY2008	\$5,400,230	36,401	96,631	223,800,000	125	-28%	25,171	Baseline

£3,900,000
€4,900,000

Stack 190







Sept. 2011 – RH setpoints for stacks with paper-based records

Adjusted from 45 +/- 5 % to 30 – 50%
with no daily maximum change



Stack 190







Jan – Feb 2011 : Tests with winter mode

Temperature: 68 +/- 2 F (20 C) lowered to 65 F (18 C)
Energy and chilled water use monitored

Dec 2012 - Implemented in stacks with paper-based records



2013 : Nighttime and weekend shutdown of AHUs




2014: Major upgrades to stack HVAC systems as part of energy savings performance contract


Constant volume units replaced with variable frequency drive (VFD) fans

Temperature, RH, and pressure sensors installed in stacks, not return ducts






Dew Point in Stack 190



Time-Weighted Preservation Index



Archives II Energy and Greenhouse Gas (GHG) Consumption and Savings

Fiscal Year	Total Utility Cost (include water)	Electric (MWH)	Natural Gas (Thous. Cu. Ft.)	Energy Usage (KBtu)	Energy Intensity (Kbtu/Gsf)	% Energy Intensity Reduction vs FY2003	GHG (Metric Ton CO2)	GHG Savings vs FY2008 (Ton)
FY2003	\$3,175,935	47,578	142,883	309,600,000	173	Baseline		
FY2008	\$5,400,230	36,401	96,631	223,800,000	125	-28%	25,171	Baseline
FY2015	\$2,935,264	26,478	73,658	166,300,000	93	-46%	17,520	-30%

Similar Storage Environment Projects

Federal Records Centers



Presidential Libraries



Specifications for Air Pollutants in Storage and Exhibit Areas

SO ₂	1.0 ppb	2.7 µg/m ³
NO ₂	2.6	5.0
Ozone	2.0	4.0
Acetic Acid	4.0	10.0
Formaldehyde	4.0	5.0

OAHU 32	OUTSIDE AIR HANDLER 25		OUTSIDE AIR HANDLER 12	
630 AHU 31A + 31B	631 AHU 24	650 AHU 23		
	←→			
530 AHU 30	532 AHU 22 35% PHOTO	550 AHU 21	570 AHU 11 2 FANS	
↑ ↓				
430 AHU 29	431 AHU 20 30% PHOTO	450 AHU 19	470 AHU 10	490 AHU 9
			←→	
330 AHU 28	331 AHU 18	350 AHU 17	370 AHU 8	390 AHU 7
↑ ↓	←→		←→	
230 AHU 27	231 AHU 16	250 AHU 15	270 AHU 6	290 AHU 5
	←→		←→	
130 AHU 26 2 FANS	131 AHU 14	150 AHU 13	170 AHU 4	190 AHU 3
	←→		←→	
				B190 AHU 2

Measurements 1994 - 2016

Outdoor AHUs effectively filter NO₂, SO₂ and ozone

NO₂ highest

Below specification in stacks

Archives 2 Stacks				
OAHU 32	OUTSIDE AIR HANDLER 25		OUTSIDE AIR HANDLER 12	
630 CLASSIFIED AHU 31A + 31B	631 CLASSIFIED AHU 24	650 AHU 23		
530 AHU 30	532 AHU 22 35%	550 AHU 21	570 AHU 11	
430 AHU 29	431 AHU 20 30%	450 AHU 19	470 AHU 10	490 CLASSIFIED AHU 9
330 AHU 28	331 AHU 18	350 AHU 17	370 AHU 8	390 AHU 7
230 AHU 27	231 AHU 16	250 AHU 15	270 AHU 6	290 AHU 5
130 AHU 26	131 AHU 14	150 AHU 13	170 AHU 4	190 AHU 3
				B190 AHU 2

Specifications for Air Pollutants in Storage and Exhibit Areas

Acetic Acid	4.0 ppb	10.0 $\mu\text{g}/\text{m}^3$
Formaldehyde	4.0	5.0

Homepage of IAP
Indoor Air Pollution Working Group

Pilot Project February 2016



NO₂ greater risk to paper records
than acetic acid

Added benefit of lower RH

Gaseous pollutant filters removed
from three stack AHUs

Rely on outside AHUs to filter NO₂

Only stacks with paper-based records

Pilot Project February 2016

Potential energy savings:
removing filters reduced static pressure
by 1" water (250 Pascals)

Filter media cost





National Archives Building Washington, DC

Constructed 1937

Major renovation and
HVAC upgrade ~2003




Outdoor NO2 Levels - 2015



Federal Records Center
Denver, Colorado
Constructed 2012

Archives 2 Electricity Use & 12-Month Time-Weighted Preservation Index (TWPI)



Acknowledgements

Preservation Programs Division, NARA

Facility & Property Management Division, NARA

LB&B Associates

Indoor Air Pollution Working Group